



State of Utah

Division of Facilities Construction and Management
4130 State Office Building Salt Lake City, Utah 84114-1002
Phone: 801-538-3263 Fax: 801-538-3378

FINE ARTS MUSEUM Roofing Improvements

Utah State University

Logan, Utah

Project Number: 05063770

Addendum Number 1

June 20, 2005

Information contained within this addendum modifies project drawings and specifications previously issued and become part of the contract documents. Acknowledge receipt of this addendum in your bid proposal.

Index to Addendum Number 1

**This cover page.
&
1 page**

Project # 05063770
Addendum Number 1
June 20, 2005

The following will apply to this specification after considering questions and concerns brought to the attention of DFCM at Pre-bid meeting on June 15, 2005

**1- The Bid date for this project has been changed to Tuesday
June 28, 2005 @ 3:00 PM**

2- Sub-list for this project will be due no later than 3:00 PM June 29, 2005

- 3- Minimum insulation R value will be R-20 above vapor barrier. EPS will not be accepted for insulation in this system.
- 4- There are two extension rings in each drain bowl. Contractor is responsible to remove them to allow for proper drainage. They may stay in place if drainage can be achieved.
- 5- Existing insulation is a combination of gypsum and EPS with a minimum thickness of 8".
- 6- Staging is very limited for this project. The dock area on the South West side of the building is the only access point. This staging area will be shared with another contractor working on this building. This contractor is Bailey Construction. Contractors should contact Alan at Bailey Construction to coordinate staging area. (435)245-6412
- 7- There will be no parking on project site. There will be the staging area and the ability to pick up and drop off. Contractors should contact Teresa Johnson at USU Parking for parking information (435)797-3480.
- 8- The sidewalk providing access to the staging area is a fire lane and needs to remain clear.
- 9- Canopy roof on North end of building will remain in bid but may have to be completed at a later date due to limited access.

Direct any concerns or Questions about project to Darrell Hunting @ 801-244-7647